



CITY OF RIVERSIDE FIRE DEPARTMENT

FIRE PREVENTION DIVISION

INFORMATIONAL BULLETIN: 2022-021

APPROVED BY: C. Kodat, Fire Marshal, 1/1/2023

HALLOWEEN MAZES AT PRIVATE RESIDENCES

Fire Department permit is not required under the following conditions:

1. Occupant loads cannot exceed a maximum of 49 persons. If occupant load is expected to exceed 49 persons a Fire Department permit will be required.
2. It is recommended that all combustible materials be flame resistant. Materials that cannot be made flame resistant should not be used.
3. A minimum 2A10BC portable fire extinguisher or a garden hose should be accessible to cover all portions of the maze.
4. You should ensure that adequate exiting from the maze is provided. It is recommended that exits be a minimum of 32 inches clear.
5. All extension cords should be heavy duty type and plugged directly into a legal outlet.

NOTE:

- Although a Fire Department permit is not required under these conditions, it is your responsibility to ensure you provide a fire safe environment for any persons entering your Halloween maze.
- These conditions do not authorize violations or cancellation of any law of the city or other city department requirements.