



FIRE FLOW REQUIREMENTS FOR BUILDINGS

DATE: January 4, 2014

INFORMATION BULLETIN: D-14-001

APPROVED BY: W. Schellhous

2013 California Fire Code, Appendix B, Section B105.2

2013 California Fire Code, Appendix B, Section B105.2 is modified to read: The minimum fire flow and flow duration for buildings other than one and two family dwellings shall be as specified in Table B105.1

Exception: A reduction of 50 percent is allowed when the building is provided with an approved automatic sprinkler system installed in accordance with Section 903.3.1.1 or 903.3.1.2. The resulting fire flow shall not be less than 1,500 gallons per minute for the prescribed duration as specified in Table B105.1