HYRDO TEST PRESSURE FOR N.F.P.A. 13D SPRINKLER SYSTEMS

DATE: February 17, 2010
INFORMATION BULLETIN: D-09-006
APPROVED BY:

Policy:

The 2002 edition of N.F.P.A. 13D, Section 4.3 is amended to read as follows:

> Hydrostatic pressure tests shall be provided in accordance with the 2002 edition of N.F.P.A. 13, standard for the installation of sprinkler systems.

Fire Prevention
3900 Main Street 3rd Floor * Riverside, California 92522 * (951) 826-5737
Fax: (951) 826-2539 * www.RiversideCa.gov/fire