HALLOWEEN MAZES AT PRIVATE RESIDENCES

DATE: January 26, 2010
INFORMATION BULLETIN: F-09-006
APPROVED BY: Michael D. Esparza

A Fire Department permit is not required under the following conditions:

A. Occupant loads can not exceed a maximum of 49 persons. If occupant load is expected to exceed 49 persons a Fire Department permit will be required.
B. It is recommended that all combustible materials be flame resistant. Materials that can not be made flame resistant should not be used.
C. A minimum 2A10BC portable fire extinguisher or a garden hose should be accessible to cover all portions of the maze.
D. You should ensure that adequate exiting from the maze is provided. It is recommended that exits be a minimum of 32 inches clear.
E. All extension cords should be heavy duty type and plugged directly into a legal outlet.

Although a Fire Department permit is not required under these conditions, it is your responsibility to ensure you provide a fire safe environment for any persons entering your Halloween maze.

These conditions do not authorize violations or cancellation of any law of the city or other city department requirements.

Fire Prevention
3900 Main Street 3rd Floor * Riverside, California 92522 * (951) 826-5737
Fax: (951) 826-2539 * www.RiversideCa.gov/fire