REQUIREMENTS FOR FIRE HYDRANTS

DATE: April 5, 2010
INFORMATION BULLETIN: D-09-005
APPROVED BY: M Esparza

Definitions:

A standard fire hydrant shall consist of one 2 ½ inch outlet and one 4 inch outlet, wet barrel.

A super fire hydrant shall consist of two 2 ½ inch outlets and one 4 inch outlet, wet barrel.

Policy:

Any construction project requiring a fire flow of 1500 gallons per minute or less shall be required to have standard fire hydrants installed.

A fire flow requirement of more than 1500 gallons per minute will require the installation of super fire hydrants.

Hydrant Markings:

Class AA 2000 GPM + are to have Green tops and Caps
Class A 1000-1999 are to have a Green Top
Class B 500-999 GPM are to have a Orange top
Class C less than 500 GPM are to have a red top

Blue reflective markers are required for private and public fire hydrants.

Fire Prevention
3900 Main Street 3rd Floor * Riverside, California 92522 * (951) 826-5737
Fax: (951) 826-2539 * www.RiversideCa.gov/fire