CASTLE VIEW PARK
R.P. #19449 J
RISER DETAIL
1-2" HDG/PVC SECONDARY RISER PER UGS-115.1 (BY U.G. CREW)
GLEN AIRE
AVE.
WEST
VIEW DR.
GREYSON
VIA VISTA DR.
MATCH LINE
MATCH LINE
BTE-3135
BTE-3136
BTE-3137
BTE-3138
V-2239
METER PED 100A MAIN 120/240V-1Ø 3 WIRE
W/ 1/0 AL XLPE TRIPLEX
★ 2½" SERVICE ENTRANCE RISER REQUIRED FOR LOT 47
TO PULLBOX ON RYCROFT DR. APPROX. 600' (WO# 7664)
STUB & CAP
ST. LT. COND. BY DEPT. W/ 2-#8 CU
RP#19446J
T-2121
PORTION
REVISED SVC. TO LOT 20 & SVC. BOX LOC.
REVISED LOC. OF TRENCHES SVC.'S & SVC. BOXES
REVISED FOR HOUSES LOTS 1-27
BWO 4093 SVC. TO CASTLE VIEW PARK
AS BUILT
SCALE 1"=50'
DATE 10-16-81
I.S. # 6402
MAP # 550, 551, 561