



A

FIXTURES SHALL BE WIDE-LITE CATALOG # SB3M-400-DR22-208-BL50-WG-SB3. ADD CSR WHERE "E" IS SHOWN ON DRAWINGS (2 LOCATIONS). PROVIDE H7-5 WIRE (INCLUDES FIXTURE HOOK, CORD AND L23-20 PLUG). SECURE TO SIDE OF JOIST WITH 3/8" SCREW EYE AND "S" HOOK. PROVIDE SC3/24 TO CABLE BALLAST TO JOIST. PROVIDE NEMA L23-20 RECEPTACLE AND WIRE PER MANUFACTURER'S DIAGRAM, INCLUDED IN THE SPECIFICATIONS. OR EQUAL BY GE. LAMP TO BE SYLVANIA # MS400/C/BU-ONLY. QUARTZ LAMP TO BE SYLVANIA # Q150DC-120V.

⚠ THERE WILL BE NO ELECTRICAL LOAD CHANGE DUE TO THE FIXTURE RETROFIT IS WATTAGE AND LAMP TYPE FOR LAMP TYPE.



PLAN CHECK CORRECTIONS 12-17-98	CITY OF RIVERSIDE, CALIFORNIA PARKS & RECREATION DEPARTMENT		GYMNASIUM LIGHTING		ACCT. NO. 220-528200-453915-00000
	PARKS MANAGER RECREATION MANAGER SENIOR PARK PLANNER	APPROVED BY DATE	APPROVED BY DATE	NICHOLS PARK 5506 DEWEY AVENUE CITY OF RIVERSIDE, CALIFORNIA	
MARK REVISIONS APPR. DATE	DESIGNED BY DRAWN BY CHECKED BY	PARK & RECREATION DIRECTOR	DATE	HORIZ. SCALE: 1/8" = 1'	

Extra