


# CITY OF RIVERSIDE

Environmental Compliance Section  
5950 Acorn Street  
Riverside, CA 92504  
(951) 351-6145




*City of Arts & Innovation*

**PUBLIC WORKS DEPARTMENT**

TO: ALL New Construction, Existing Construction, and  
Tenant Improvements

FROM: Environmental Compliance Section,  
City of Riverside, Public Works Department

SUBJECT: Approved Design Criteria for Sampling Station



## NOTE:

1. Barrel diameter of sampling wye to be a minimum of 2 inches larger than building discharge line.
2. Diameter of riser pipe to be 4 inches.
3. Must be accessible at all times to City personnel.
4. Not for use in traveled ways.
5. If necessary to place cap in sidewalk, use flush cap.