

ELECTRIC RULE 8

TEMPORARY ELECTRIC SERVICE

A. DEFINITIONS

Temporary electric service is electric service for fairs, circuses, bazaars, temporary restaurants and other establishments not of a permanent nature, and electric service for construction purposes.

B. USES AND APPLICATIONS

The Utility shall furnish one temporary service per location under the following conditions:

1. The Applicant shall pay in advance the estimated net cost of installation and removal of facilities necessary to furnish temporary service.
2. Where service is to be supplied overhead and can be supplied from existing facilities by installation of a single span of overhead service conductors, not to exceed 100 feet in length, a charge shall be made for 120/240 volts, 3-wire, single-phase service up to 200 amps.
3. Where it is necessary to install a temporary overhead transformer, a charge shall be made to cover the installation and removal costs of the transformer and service drop.
4. Where service is to be supplied underground and can be supplied from existing facilities or from facilities being installed for permanent service, a charge shall be made for 120/240 or 120/208 volts, 3-wire, single-phase service up to 200 amps and not exceeding 20 feet in length.
5. Where it is necessary to install a temporary padmounted transformer for a temporary service of 120/240 volts, 3-wire, single-phase, a charge shall be made to cover the installation and removal costs of the transformer and service wire.
6. Each Applicant for temporary service may be required to establish credit in accordance with Rule No. 3.
7. Any temporary service larger than 200 amps, single-phase or requiring more work than covered in paragraphs 1 through 5 above, will require an engineering estimate and payment of the cost.

