



Revision



GENERAL SPECIFICATIONS FOR MULE TAPE

UGS

REVISION: New Requirement is Mule Tape

REVISION DATE: 01/04/10

APPROVED BY: Cesar Ancheta

APPROVED DATE: 01/07/10

PREPARED BY: JRS

CHECKED BY: CA

GENERAL DESCRIPTION

This specification covers the minimum requirement for Mule Tape to be installed in the City of Riverside Public Utilities Department conduit system. The Mule Tape is generally provided and installed by a contractor. The Mule Tape will be used by the Department to pull "bull" lines into the conduit system during the installation of electrical distribution cable.

MATERIAL

Mule Tape shall have clearly printed sequential footage, strand rope will not be acceptable, shall be:

- Manufactured from a flat, woven polyester material of low elongation;
- Lubricated to reduce friction; and,
- Light enough to be blown into conduit or inner duct.

SIZE AND STRENGTH

Mule Tape shall have a minimum width of 3/4 inch and a minimum average tensile strength of 2500 pounds. No knots are allowed.



ACCEPTABLE MULE TAPE.

The following are Department approved Mule Tape Manufacturer(s) :

- Neptco

Mule Tape may be obtained from the following supplier(s) :

- Cal-Duct Inc.