


TYPE A OR B ENCASEMENT FOR WATER & SEWER
 REQUIRED TO SPAN TRENCH, OR WHERE ENCASEMENT
 IS NOT POURED ON UNDISTURBED EARTH

NOTE:

- ① EXTEND MACHINED PIPE ENDS BEYOND ENCASEMENT
- ② SEE CWD-023-2 FOR CROSS-SECTION OF A, B, OR C ENCASEMENT DETAIL
- ③ PIPE JOINT TYPES AND MATERIALS ARE PER GREEN BOOK SECTION 208



TYPE C ENCASEMENT FOR WATER & SEWER



WATER DISTRIBUTION & TRANSMISSION
 PIPELINE CONSTRUCTION METHODS

STRUCTURE INTERFERENCE
 TYPE A, B, OR C ENCASEMENT