



NOTES

- 1.) FLANGE INSULATION GASKETS SHALL BE FULL-FACED, NEOPRENE-COATED FABRIC-REINFORCED PHENOLIC, 1/8 INCH THICK. A ONE-PIECE SLEEVE AND WASHER, SEPARATE PHENOLIC WASHER, AND TWO CADMIUM-PLATED STEEL WASHERS SHALL BE USED FOR EACH BOLT OR CAP SCREW.
- 2.) FLANGE KITS SHALL BE FURNISHED IN ACCORDANCE WITH THE SPECIFICATIONS.
- 3.) TEST LEAD CONNECTIONS AND LOCATIONS IN ACCORDANCE WITH CWD-922.
- 4.) TEST LEADS SHALL BE TAGGED AND/OR COLOR-CODED EAST/WEST OR NORTH/SOUTH OF VALVE.
- 5.) TEST LEAD INSULATION KIT SHALL BE STRIPPED BACK ONE INCH FROM ENDS.
- 6.) WHEN FLANGE KITS ARE SPECIFIED: SIZE _____ - 150# - TYPE EN-DW.



WATER DISTRIBUTION & TRANSMISSION
PIPELINE CONSTRUCTION METHODS

**FLANGE INSULATION
AND TEST LEAD INSTALLATION**