



NOTES

- 1.) SEE PLAN FOR "A" DIMENSION (8" MIN)
- 2.) BACKFILL SHALL BE BROUGHT UP UNIFORMLY ON BOTH SIDES OF WALL.
- 3.) CEMENT: TYPE 1 OR 2
ASTM 5150, 2000 PSI
- 4.) REINFORCEMENT: GRADE 40 OR
GRADE 60, ASTM A 615
- 5.) TRENCH WIDTH: OD PIPE + 18" MIN



WATER DISTRIBUTION & TRANSMISSION
PIPELINE CONSTRUCTION METHODS

TYPICAL CONDUIT SUPPORT